


- All the dimensions are shown in millimetres
- Tubes 40mm x 30mm
- Bracket length 50mm
- ½ inch BSP bottom underside connections
- Test pressure: 10 Bar
- -Max working temperature: 8 Bar
- Heat output in accordance with EN 442

## Please Note:

- Please allow minimum of 100mm for valves
- Summer Element use will affect pipe centres
- The flow and return can be reversed

Aztec	Water Content (L)	Weight (KG)	Pipe Centres +/- 2mm	Fixing Centres (H) +/- 2mm	Fixing Centres (W) +/- 2mm	Height (mm)	Width (mm)
RXAZ-0915500	3.95	6.23	460	875	460	915	500
RXAZ-1265600	6.08	9.61	560	1225	560	1265	600
RXAZ-1615600	7.62	12.04	560	1575	560	1615	600

## Installation:



Step 1: Select the desired mounting position, make sure the wall is adequate to take the fixing points of the rail i.e anchor points must be securely attached to a stud or masonry.

Step 2: Loosely screw the wall support (Part 2) into the wall using the wall screw (5) and washer. Use wall plug (1) if you are fixing into masonry. Do no tighten fully.

**Step 3:** Manoeuvre the rail back onto the bracket and tighten with the grub screw (3).

## Cleaning:

- Do not use any abrasive or chemical cleaners to clean the radiators as this will cause damage to the surface finish. Please use warm water and a damp cloth.
- Do not clean when hot.